Bangalore Development Authority

Name of the Work:Providing LED Street Lights with Centralized Control and Monitoring System (CCMS) for sector 1 to 9 at Dr K Shivarama Karanata Layout

Tender Indent No:BDA/2025-26/EL/WORK_INDENT95

Sr. No.	Clause no.	As per Bid Document	Queries / Sugessions with Justification	Clarifcation by BDA
1	1.3	Note:The documentary proof of fulfilling the qualifying requirements shall be uploaded along with the bid. The bidder shall upload the Work Done Certificates, Performance Certificates issued by end users not below the rank of Executive/ Divisional Engineer along with the bid.	We request you to change the clause as Work Done Certificates or Performance Certificates. As it may not be feasible to arrange performance certificates within the bidding time from Govt clients	Tender Condition Prevails
2	ANX-V	Power of Attorney	We request you to accept General power of Attorney instead of specific POA.	Tender Condition Prevails
3	BOQ Sl no:10 & 11	Wiring for lighting/power circuit using one of FRLS PVC insulated 1100V grade, multistrand copper wire with low conductor resistance single core in open or concealed system of wiring with specified IS-694:2010, 1.5 mm2 & 2.5 mm2	1.5 Sqmm wire & 2.5 Sqmm wire has been given for pole bottom MCB to LED fitting(we request BDA to conisder 3Cx2.5 Sqmm Cu cable instead of Cu wire for work feasibility-as if wire is considered there may be higher chances of wire damage/sleeve cuttings etc., as pole is already installed we need to remove the arm & re-fit again)	Tender Condition Prevails
4	BOQ Sln:26	Digging of pit for providing GI pipe Earthing-ordinary soil	Quantity of pit is not matching with quantity of other earthing items. Please check and confirm.	Tender Condition Prevails
5	BOQ Sln:40	Fabricating supplying and mounting MS box made out .SWG suitable for floor / wall mounting, fully weather proof with provision for better heat dissipation, provided with hinged front cover, equipped with tamper proof locking arrangements, with suitable size clA with necessary cable entry pipe with gland and box should be finished with 7tanks treatment with powder coated paint and finally finished with approved colour etc., complete. 14 SWG complete with all lead and lift, as perKPWD norms and direction of the engineer in charge of work.	Can we consider IFP/Controller & Motion Sensor enclosure in this MS Box item.	Tender Condition Prevails
6	BOQ Sln:33	Supplying and drawing Flexible Multicore Cable manufactured with electrolytic grade flexible copper with low conductor confirming to IS 8130-1984 and (Virgin) PVC insulation sheathed suitable for working voltage upto 1100V as per IS- 694:2010 4C x 16 mm2 complete with all lead and lift, as perKPWD norms and direction of the engineer in charge of work.	Please confirm if it is for Highmast Trailing cable	Tender Condition Prevails

ಕಾರ್ಯಪಾಲಕ ಇಂಜಿನೀಯರ್ (ವಿದ್ಯುತ್)
ವಿದ್ಯುತ್ ವಿಭಾಗ
ಬೆಂ. ಅ. ಪ್ರಾ, ಬೆಂಗಳೂರು

Scanned with OKEN Scanner